

UFE reasonableness report								
Last Revision Date:		27-Nov-20						
Period (Day / Month)	Date Identified	Test 1 General	Test 2 LSA Avg	Settlement Run (in accordance with Section 4.4)	Type of Error	Status	Date Resolved	Comments
	Date Identified by the LSA	Outside of Overall Bound (mark with 'x')	Outside of LSA-specific bound (mark with 'x')	I=Initial Daily M=Initial Monthly R=Interim F=Final	S=System Level I= Interval C=Cumulative D=Deemed O=LSA Operational U=Unidentified	(1) Open-LSA (2) Open-Other (3) Resolved	Date when LSA or other responsible party has resolved the issue	
July 2020	November 26, 2020		X	F	D	3		<p>Monthly average SSI UFE % for July 2020 final settlement run is -2.6734%, which is lower than the settlement zone-specific UFE tolerance of -2.6%. In particular, average daily UFE % for each of the first three days of the month fell outside of the tolerance range.</p> <p>It is largely due to a significant increase in deemed IRRIGATION2004 profile from Jun to July, whereas no substantial weather change around that time was reported.</p>