

UFE Reasonableness Report								
Last Revision Date:		14-Mar-2023						
Period (Day/Month)	Date Identified	Test 1 General	Test 2 LSA Avg	Settlement Run (in accordance with Section 4.4)	Type of Error	Status	Date Resolved	Comments
	Date Identified by the LSA	Outside of Overall Bound (mark with 'x')	Outside of LSA-specific bound (mark with 'x')	I=Initial Daily M=Initial Monthly R=Interim F=Final	S=System Level I=Interval C=Cumulative D=Deemed O=LSA Operational U=Unidentified	(1) Open-LSA (2) Open-Other (3) Resolved	Date when LSA or other responsible party has resolved the issue	
Oct-2022	24-Feb-2023		x	F	C	3	2-Oct-2022	Daily average UFE on 1-Oct-2022 reached 1.4 percent, exceeding the upper bound of the monthly tolerance range of 1.2 percent set for FortisAlberta based on prior year results. This was due to the seasonal change of the monthly deemed profile for irrigation, causing the allocated energy of irrigation consumption on the first day of October to be less than the actual energy usage. This was offset by higher allocation of energy on the days that followed.
May-2022	28-Sep-2022		x	F	C	3	29-Sep-2022	Daily average UFE on 31-May-2022 reached 1.36 percent, exceeding the upper bound of the tolerance range at 1.2 percent. This is due to the seasonal change of the monthly deemed profile for irrigation causing the allocated portion of irrigation consumption on the last day of May to be less than the actual usage. This was offset by higher allocation during the first days of June for sites with actual reads starting on May 31.